

PRODUCT-DETAILS

F204 AC-40/0.3 F204 AC-40/0.3 Residual Current Circuit Breaker



| General Information | |
|-----------------------|--|
| Extended Product Type | F204 AC-40/0.3 |
| Product ID | 2CSF204001R3400 |
| EAN | 8012542781905 |
| Catalog Description | F204 AC-40/0.3 Residual Current Circuit Breaker |
| Long Description | The RCCBs F200 series assures protection to people and installations against fault current to earth. A large offer for standard instantaneous and selective AC and A types is completed with some configurations for special applications. |

| Technical | |
|--|-------------------------|
| Standards | IEC/EN 61008 UL 1053 |
| Type of Residual Current | AC type |
| Rated Voltage (U _r) | 230/400 V |
| Rated Operational Voltage | 230 / 400 V AC |
| Rated Insulation Voltage (U _i) | 500 V |
| Rated Impulse Withstand Voltage (U _{imp}) | 4 kV |
| Rated Current (I _n) | 40 A |
| Rated Residual Current | 300 mA |

| Rated Conditional Short- Circuit Current (I _{nc}) | 10 kA |
|---|--|
| Rated Service Short- Circuit Breaking Capacity (I _{cs}) | 1 kA |
| Maximum Surge Current | 0.25 kA |
| Leakage Current Type | AC |
| Rated Frequency (f) | 50 / 60 Hz |
| Power Loss | at Rated Operating Conditions per Pole 3.2 W |
| Power Supply Connection | Arbitrary |
| Electrical Endurance | 10000 cycle |
| Number of Poles | 4 |
| Operating Characteristic | Instantaneous |
| Position of Neutral Terminals | Right |
| Mounting Type | DIN rail |
| Options Provided | None |
| Accessories Available | Yes |
| Connecting Capacity | Busbar 10 mm² Rigid 25 25 mm² Flexible 25 25 mm² |
| Rated Cross-Section | 4 - Multi-Wired 025 mm² 1 - Solid-Core 2525 mm² |
| Ambient Temperature | -2555 °C |
| Ambient Air Temperature | Operation -2555 °C |
| Degree of Protection | IP2X |
| Pollution Degree | 2 |
| Resistance to Vibrations acc. to IEC 60068-2-6 | 0.1 mm or 1 g - 20 cycles at 5…150…5 Hz |
| Resistance to Shock acc. to IEC 60068-2-27 | 25g / 2 shocks / 13 ms |
| RoHS Status | Following EU Directive 2011/65/EU |
| Environmental Information | Refer to RoHS |
| Technical UL/CSA | |
| Maximum Operating Voltage UL/CSA | 480Y / 277 V AC |
| Short-Circuit Current Rating (SCCR) | 300 mA |
| Dimensions | |
| | |
| Width in Number of Modular Spacings | 4 |
| | 4 0.070 m |
| Modular Spacings | |

| Length | |
|----------------------------------|----------|
| Product Net Weight | 0.360 kg |
| Built-In Depth (t ₂) | 69 mm |

| Container Information | |
|-----------------------------------|---------------|
| Package Level 1 Units | box 1 piece |
| Package Level 1 Width | 80 mm |
| Package Level 1 Height | 41 mm |
| Package Level 1 Depth / Length | 94 mm |
| Package Level 1 Gross Weight | 0.415 kg |
| Package Level 1 EAN | 8012542781905 |

| Ordering | |
|------------------------|------------|
| Minimum Order Quantity | 1 piece |
| Customs Tariff Number | 85363030 |
| Country of Origin | Italy (IT) |

| Declaration of Conformity - CE | 9AKK106713A5602 |
|-----------------------------------|-----------------|
| Environmental Information | Refer to RoHS |
| Instructions and Manuals | 9AKK107991A6127 |
| RoHS Information | 2CSC423001K2702 |

| Data Sheet, Technical Information | 9AKK107991A8329 |
|--------------------------------------|-----------------|
| Instructions and Manuals | 9AKK107991A6127 |

| Classifications | |
|------------------------------|--|
| ETIM 7 | EC000003 - Residual current circuit breaker (RCCB) |
| ETIM 8 | EC000003 - Residual current circuit breaker (RCCB) |
| EPLAN Catalog Tree | Electrical engineering / Protection devices / Ground fault current circuit breaker |
| EPLAN Function Definition | Ground fault current circuit-breaker / Ground fault current circuit breakers, 8 connection points / Ground fault current circuit breaker, four-pole 1_2_3_4_5_6_N_N. |
| WEEE Category | 5. Small Equipment (No External Dimension More Than 50 cm) |
| WEEE B2C / B2B | Business To Consumer |
| CN8 | 85363030 |
| Object Classification Code | F |

Categories

Low Voltage Products and Systems \rightarrow Modular DIN Rail Products \rightarrow Residual Current Devices RCDs \rightarrow Residual Current Devices RCDs





